



# Bennett & Bennett

Consulting Surveyors, Development Consultants  
& Town Planners

T.S.S.

99 Upton Street,  
Bundall, Qld. 4217

88.034.A27-GWS:lp

15 September 1998

All mail to:  
P.O. Box 6021  
Gold Coast Mail Centre  
Qld. 9736

Ph (07) 5574 0733  
Fax (07) 5574 0202  
Email: bennbenn  
@qldnet.com.au

## CERTIFICATE



### DIRECTORS

S.T. Hudson  
B. Surv. L.S. MIS (Aust)  
(Qld. NSW)

P.M. Ireland  
B. Surv. L.S. MIS (Aust)  
(Qld. NSW)

G.W. Short  
A.D. App.Sc. AACs

G.F. Pennycuik  
B. Surv. L.S. MIS (Aust)

R.J. McAllister  
B. Surv. L.S. MIS (Aust)



### CONSULTANTS

E.B. Bennett  
B. Surv. L.S. MIS (Aust)

W.L. Bennett  
L.S. MIS (Aust)




### SENIOR PLANNER

R.S. Heatley  
B.R.T.P., B.A.  
M.R.A.P.I.

B.B.H. Pty Ltd  
ACN 010 427 531  
trading as  
Bennett & Bennett  
Consulting Surveyors  
Established 1968  
Member Firm ACS (Qld)  
Licensed in Qld & NSW

BBH PTY LTD (ACN 010427531), Licensed Surveyor, of 99 Upton Street, Bundall, HEREBY CERTIFIES that it had inspected the swimming pool constructed on Lot 1 on RP 189503, Parish of Nerang, County of Ward in July 1990, being the grounds of the Southport School and report the following.

The distance between the tiles on both end walls at all points measured from 0.3 metres above to 0.8 metres below the waterline, is not less than 50.035 metres and not more than 50.045 metres.



LICENSED SURVEYOR



# Bennett & Bennett

Consulting Surveyors, Development Consultants  
& Town Planners



Our Ref: 06.397

T.S.S.  
31<sup>st</sup> October, 2006

## CERTIFICATE

BBH PTY LTD (ACN 010427531), Cadastral Surveyor, of 95 Upton Street, Bundall, Qld. HEREBY CERTIFIES that the Company has inspected the 50 metre outdoor swimming pool at the Southport School, Winchester Street, Southport, that the raised steps at each end of the pool are 0.3 metres above the water level, that the depth of water at a distance of 0.25 metres from each end wall is 1.2 metres, and that the highest point of the starting blocks is 0.73 metres above the water level.

  
.....  
DIRECTOR

  
.....  
DIRECTOR



CADASTRAL SURVEYOR

**MAIN OFFICE**  
95 Upton Street,  
Bundall, Qld. 4217  
**Postal Address**  
PO Box 5021,  
GCMC, Qld. 9726  
Ph (07) 5574 0733  
Fax (07) 5574 0202  
Email:  
mail@bennettandbennett.  
com.au  
Web:  
www.bennettandbennett.  
com.au

**Coomera Office**  
1/21 Dreamworld Pkwy,  
Coomera, Qld. 4209  
Ph (07) 55 736177  
Fax (07) 55 294342

**Brisbane Office**  
Level 3, 490  
Upper Edward Street,  
Spring Hill, Qld. 4004  
Ph (07) 3839 7200  
Fax (07) 3839 7277

### DIRECTORS

G.W. Short  
Grad. Dip. Urb. & Reg.  
Planning  
PIA (Aust)

P.M. Ireland  
B. Surv. L.S. MIS (Aust)

G.F. Pennycuik  
B. Surv. L.S. MIS (Aust)

R.J. McAllister  
B. Surv. L.S. MIS (Aust)

P.D. Jones  
B.App.Sc (Sury)  
L.S. MIS (Aust)

### CONSULTANTS

A. Van  
L.S. Dip TRP MPIA

S.T. Hudson  
B. Surv. L.S. MIS (Aust)  
(Qld. NSW)

B.B.H. Pty Ltd  
ACN 010 427 531  
trading as  
Bennett & Bennett  
Consulting Surveyors  
Established 1968  
Member Firm ACS (Qld)

